



Wildfire

Building Risk Assessment Form

Wildfire Building Risk Assessment			
Head Start Program: _____			
	Y	N	Necessary Action
Do you have fire insurance?			
Are information systems and vital records securely backed up offsite?			
Are gas and electric power systems, and sewer lines located near evacuation routes or exterior assembly areas?			
Are all utility shutoff points located and labeled appropriately?			
Are the tools for shutting off lines handy?			
Is the facility located within a defensible space, e.g., a radius of 100 feet around the building cleared of materials that can ignite from embers?			
Are all flammable materials stored at least 30 feet from the structure?			
Does the property include fire-resistant landscaping?			
Are trees pruned to at least 10 feet above the ground to thwart crown fire?			
Is the roof of the building made of noncombustible materials?			
Are vents covered with 1/8" wire mesh to block embers?			
Are gutters and roof free of flammable debris?			
Are exterior wall surfaces composed of noncombustible or fire-resistant materials?			
Do windows contain multi-pane, tempered glass, or fireproof shutters?			
Are eaves boxed in with fire-resistant materials?			
Do driveways and walkways provide a fuel break?			
Are exterior play structures made of non-flammable materials?			



ADMINISTRATION FOR
CHILDREN & FAMILIES



National Center on
Program Management and Fiscal Operations